

## Paxton Two Stage Replacement Filter Elements

**MODEL # 1M-800-R2**

1 micron  
800 cfm, maximum flow



Item Number	1M-800-R2	
Description	Replacement Filter Elements with Pre-filters, 2 pack	
Fits blowers	XT-500, AT-700	
Efficiency	99% @ 1 micron, nominal	
Maximum Flow Rate	800 scfm	23 m <sup>3</sup> /min
Maximum Operating Temperature	185°F	85°C
Initial Operating Pressure	1.5° H <sub>2</sub> O	38 mm H <sub>2</sub> O
Maximum Pressure Drop	12° H <sub>2</sub> O	305 mm H <sub>2</sub> O
Media	Reinforced polyester, hydrophobic, water repelling, non-absorbing, oil resistant	
Material of Construction	Steel, powder coat finish, corrosion resistant	
Weight, each	2.5 lbs	1.1 kg
Dimensions		
Length	9 1/4 in	235 mm
Diameter	10 in	254 mm

### Related Components

Item Number	1200-Silencer	
Description	Silencer Cartridge: attenuates noise up to 8 dB	
Dimensions		
Length	6 3/4 in	171 mm
Diameter	5 1/2 in	140 mm
Weight	2 lbs	0.9 kg

### Recommended Replacement Frequency

Paxton part	1 or 2 shifts/day operation	3 shifts/day operation
Belts	12 months	6 months or 4000 hours
Belt Springs	12 months	6 months or 4000 hours
Tensioners	24 months	12 months
Filters	Filters must be changed as often as needed to maintain blower or system performance as measured by increased pressure drop across the filter. The filter must be changed if the pressure drop exceeds 10" of water column. Filter change frequency will vary widely based on environmental and atmospheric conditions. Minimum recommended filter change frequency is every 12 months for 1 or 2 shift/day operation; and every 6 months for 3 shift/day operation.	

